Date Issued: December 2015	Page No.: 1	Document No.: SOP-LAB-01
Revision: 1.1	Subject: Fume Hoods – Procedures for Installation, Maintenance and Use	

1.0 Introduction

The Standard Operating Procedure for Fume Hoods was developed by the Department of Environmental Health and Safety (EH&S) in conjunction with Physical Plant Services, in accordance with the University Policy Statement on Health and Safety and to ensure compliance with the applicable legislation governing the installation, maintenance and use of Fume Hoods.

Applicable Legislation:

- CSA-Z316.5-15 Fume Hoods and Associated Exhaust Systems
- ANSI/AIHA (American National Standards Institute/American Industrial Hygiene Association), Z9.5-2003 Laboratory Ventilation
- ASHRAE (American Society of Heating, Refrigeration and Air-Conditioning Engineers), 110-1995 Method of Testing Performance of Laboratory Fume Hoods
- 2012 ASHRAE Handbook – HVAC Systems and Equipment
- Occupational Health and Safety Act, R.S.O. 1990
- Canada Occupational Health and Safety Regulations, SOR/86-304
- Canadian Environmental Protection Act, S.C. 1999, c. 33
- Nuclear Safety and Control Act, S.C. 1007, c. 9
- National Building Code of Canada, 2010
- National Fire Code of Canada, 2010
- NFPA (National Fire Protection Association), 45 (2015)

Date Issued: December 2015	Page No.: 4	Document No.: SOP-LAB-01
Revision: 1.1	Subject: Fume Hoods – Procedures for Installation, Maintenance and Use	

when working with fume hoods.

- ð Ensure that all employees and students have received instructions in the proper operation of fume hoods.
- ð Ensure that procedures, equipment and materials appropriate for the fume hoods under his/her authority are provided to protect the health and safety of all employees and students.
- ð Ensure that all employees and students are given adequate supervision and instructions on the hazards of chemical usage and fume hood operation.
- ð Ensure that mechanical

(Note: Acid digestions using acids other than perchloric should be performed in fume hoods designed to withstand the corrosive and damaging effects of repeated manipulations using acid. Consult with Physical Plant Services or the Department of Environmental Health and Safety for further information.)

4.4 Recirculating (Ductless) Fume Hoods

It is the policy of the Department of Environmental Health and Safety not to allow recirculating fume hoods to be used on campus for several reasons:

- They have limited use because of the wide variety of chemicals used at Queen's University;
- The use of inappropriate chemicals or compounds or other misuses of the recirculating fume hood could resulting contaminated air being recirculated into the laboratory; and
- It is difficult to de m tیی ئر M c

Supply air should be at a suitable temperature to be acceptable by laboratory users.

7.0 Training

A training program shall be

Date Issued: December 2015	Page No.: 12	Document No.: SOP-LAB-01
Revision: 1.1	Subject: Fume Hoods – Procedures for Installation, Maintenance and Use	

Appendix A
Application For Fume Hood Procurement / Installation

Contact Person:	Phone Number:

Location Information:

Building:	Room/Location:
Anticipated Installation Date:	Campus Department:

Fume Hood Information:

Type of Fume hood (including make and model):

Will this hood replace an existing fume hood? Yes No
Has the area been engineered to support the hood? Yes No
If yes, by whom (ex. PPS engineer): _____;
When _____
Has a list of chemicals to be used in this fume hood been submitted to EH&S Yes No
Area Manager Approval: _____
Additional Details: (Attach schematic drawings, designs, sketches etc.)